



Foundation Depths Due To Tree

Foundation 1.0m from tree - Min. depth 2.20m
Foundation 2.0m from tree - Min. depth 1.95m
Foundation 3.0m from tree - Min. depth 1.70m
Foundation 4.0m from tree - Min. depth 1.50m
Foundation 5.0m from tree - Min. depth 1.25m
Foundation 6.0m from tree - Min. depth 1.20m

Revisions

- A - Revisions to client's requirements.
- B - Revisions to Planning Requirements.

Proposed beams and supports/bearings to structural engineer's design.

SD - Smoke Detector

Notes

The contractor is responsible for checking dimensions on site before work is carried out.
 SGT Building Design to be notified of any discrepancies.
 © SGT Building Design unless otherwise agreed.

SGT Building Design

drawing title
Extensions and Alterations

site

scale 1:50
 date

drawing no. 8000-03
 revision B

Proposed Ground Floor Plan